RULE 215 TRANSFER OF GASOLINE INTO TANK TRUCKS, TRAILERS AND RAILROAD TANK CARS AT LOADING FACILITIES

Adopted 6-19-79 (Amended 9-25-90, 11-03-94, 6-19-97)

CONTENTS

100	GENERAL	
		PURPOSE APPLICABILITY
200	DEFINITIONS	
	202 203 204 205 206 207 208 209 210 211	BULK PLANT BULK TERMINAL CAPACITY EXEMPT COMPOUNDS GASOLINE GASOLINE VAPORS LEAK FREE ORGANIC LIQUID REID VAPOR PRESSURE SWITCH LOADING VAPOR TIGHT VOLATILE ORGANIC COMPOUNDS
300	STANDARDS	
		TRANSFER PROVISIONS OTHER OPERATING REQUIREMENTS
400	ADMINISTRATIVE REQUIREMENTS	
	401	COMPLIANCE SCHEDULE
500	MONITORING AND RECORDS	
		RECORDKEEPING TEST METHODS

This Page Intentionally Left Blank

100 GENERAL

PURPOSE: To limit the emissions of volatile organic compounds (VOC) during gasoline transfer operations at bulk plants and bulk terminals.

102 APPLICABILITY:

- 102.1 Geographic: This provisions of this rule apply to all of Placer County.
- 102.2 <u>Business Function</u>: This rule applies to any bulk plant or bulk terminal where gasoline is loaded into a truck, trailer or railroad tank car, and to any person who owns, operates or is employed at such facility.

200 DEFINITIONS

- **BULK PLANT:** A gasoline distribution facility which receives gasoline exclusively by tank truck from a refinery or bulk terminal and has a throughput less than or equal to 20,000 gallons per day or 5,000,000 gallons per year.
- **BULK TERMINAL:** A gasoline distribution facility which receives gasoline from a refinery by pipeline, ship, or barge and has a throughput greater than 20,000 gallons per day or 5,000,000 gallons per year.
- **203 CAPACITY:** The maximum volumetric quantity of liquid that may be stored in a tank.
- **204 EXEMPT COMPOUNDS:** Exempt compounds are as defined in Rule 102, Definitions.
- **205 GASOLINE:** Any organic liquid (including petroleum distillates and methanol) having a Reid Vapor Pressure of 4.0 pounds or greater and used as a motor vehicle fuel, or any fuel which is commonly or commercially known or sold as gasoline.
- **206** GASOLINE VAPORS: The displaced vapors including any entrained liquid gasoline.
- **LEAK FREE:** Any liquid leak of less than three drops per minute excluding losses which occur upon disconnecting transfer fittings, provided such disconnect losses do not exceed 10 milliliters (0.34 fluid ounces) per disconnect, averaged over three contiguous disconnects.
- **208 ORGANIC LIQUID:** Any volatile organic compound which contains hydrogen and which would exist as a liquid at actual conditions of use or storage.
- **REID VAPOR PRESSURE:** The absolute vapor pressure of volatile crude oil and volatile non-viscous petroleum liquids, except liquefied petroleum gases, and determined by ASTM-323-58.
- **SWITCH LOADING:** The transfer of organic liquids with a Reid Vapor Pressure of less than 4.0 lbs into a delivery vessel where the previous load was gasoline.
- **211 VAPOR TIGHT:** A condition when the concentration of total hydrocarbons does not exceed 10,000 ppm (expressed as methane) above background, as determined by EPA Reference Method 21. Background shall be defined as the ambient concentration of organic compounds determined at least three (3) meters upwind of the potential source and not influenced by any specific emissions source.
- **212 VOLATILE ORGANIC COMPOUNDS:** Compounds which contain at least one atom of carbon, except for the Exempt Compounds.

300 STANDARDS

301 TRANSFER PROVISIONS:

- 301.1 <u>Vapor Recovery System Certification</u>: A person shall not load gasoline into any tank truck, trailer, or railroad tank car from any bulk plant or bulk terminal, unless the loading device or equipment is equipped with a California Air Resources Board certified vapor recovery and disposal system.
- 301.2 <u>Loading Procedures:</u> Loading shall be accomplished in such a manner that all displaced vapor and air will be vented only to the vapor recovery system. Measures shall be taken to ensure complete drainage before the loading device is disconnected and the loading device shall be maintained in a vapor tight and leak free condition when not in use.
- 301.3 <u>Bulk Plants:</u> A person shall not transfer or permit the transfer of gasoline into any tank truck, trailer, or railroad tank car unless the emission of gasoline vapors and gases to the atmosphere does not exceed 0.6 pounds of Volatile Organic Compounds (VOC) per one thousand (1,000) gallons of gasoline transferred as determined by a method specified in Section 502.1.
- 301.4 <u>Bulk Terminals:</u> A person shall not transfer or permit the transfer of gasoline into any tank, truck, trailer, or railroad tank car unless the emission of gasoline vapors and gases to the atmosphere does not exceed 0.08 pounds of Volatile Organic Compounds (VOC) per one thousand (1,000) gallons of gasoline transferred as determined by the method specified in Section 502.2.

302 OTHER OPERATING REQUIREMENTS:

- The loading facility vapor recovery system shall not create a back-pressure in excess of the pressure limits of the delivery vessel certification leak test (18 inches of water gauge).
- 302.2 All vapor recovery equipment and gasoline loading equipment shall be maintained in good working order and shall be leak free and vapor tight.
- 302.3 Switch loading shall be subject to Sections 301.3 and 301.4 of this rule.
- 302.4 Transfer equipment shall be configured to require that the gasoline delivery vessel be bottom loaded.
- 302.5 In no instance shall the gasoline loading operations exceed the capacity of the vapor processing unit.

400 ADMINISTRATIVE REQUIREMENTS

401 COMPLIANCE SCHEDULE:

401.1 By November 3, 1995, any person subject to this rule shall submit an application for Authority to Construct for any modifications required to achieve compliance with the requirements of this rule.

401.2 By November 3, 1996, any person subject to this rule shall demonstrate final compliance with all applicable standards and requirements of this rule. Compliance with Section 301 shall constitute compliance with Section 401 unless it is determined that the equipment does not comply with section 301.3 and 301.4.

500.MONITORING AND RECORDS

501 RECORDKEEPING:

- 501.1 The owner or operator of any facility subject to the provisions of this rule shall prepare a daily log of the throughput and a summary of the throughput for the calendar year to date of the liquid compounds subject to the provisions of this rule. Such records shall be retained at the facility for at least 2 years, and shall be retained for at least 5 years for sources subject to the requirements of Rule 507, Federal Operating Permit Program, and shall be made available to the Air Pollution Control Officer upon request.
- 501.2 Records shall include the number of petroleum storage tanks serviced and their respective capacities in gallons.
- 501.3 In addition to the recordkeeping requirements specified herein, all provisions of Rule 410, Recordkeeping for Organic Compound Emissions, shall apply.
- **TEST METHODS:** Reference test methods for compliance testing shall be the following, as applicable:
 - 502.1 California Air Resources Board Test Method TP 202.1, "Determination of Emission Factors of Vapor Recovery Systems at Gasoline Bulk Plants".
 - 502.2 California Air Resources Board Test Method TP 203.1, "Determination of Emission Factors of Vapor Recovery Systems at Gasoline Terminals".
 - 502.3 EPA Reference Method 21 shall be used to test for vapor tight condition or liquid leaks.

This Page Intentionally Left Blank